




e-ISSN: 2548-060X

## International Journal of Energy Applications and Technologies

journal homepage: [www.dergipark.gov.tr/ijeat](http://www.dergipark.gov.tr/ijeat)

Original Research Article

### Greenough River Solar Farm case study & validation initialization

Angus King<sup>1</sup>, Burak Ömer Saraçoğlu<sup>2,\*</sup><sup>1</sup> Tech Team, Sustainable Energy Now Inc., Perth, WA, Australia<sup>2</sup> Orhantepe Mahallesi, Tekel Caddesi, Geziyolu Sokak, 34865 Dragos, Kartal, Istanbul, Turkey

#### ARTICLE INFO

\* Corresponding author  
[burakomersaracoglu@hotmail.com](mailto:burakomersaracoglu@hotmail.com)

Received May 3, 2018  
 Accepted September 23, 2018

Published by Editorial Board  
 Members of IJEAT

© This article is distributed by  
 Turk Journal Park System under  
 the CC 4.0 terms and conditions.

doi:10.31593/ijeat.420701

#### ABSTRACT

Large Photovoltaic Solar Power Plants (LPVPPs) and Very Large Photovoltaic Solar Power Plants (VLPVPPs) may have rapid success in the revolutionary change of the national and international power grids to build a 100% renewable power Global Grid. The Australian continent has outstanding solar resource availability, enabling widespread utilization of solar power and power storage technologies (e.g. pumped hydroelectric, thermal, electrochemical). Design and investment modeling of the renewable power grid is the success key for a 100% renewable power grid. The design and investment in LPVPPs and VLPVPPs should preferably be undertaken with the consideration of values such as environmental friendliness, fairness, openness to small private investors, reliability, and accountability. The design of LPVPPs and VLPVPPs should preferably be based on some small-scale PV power plants to help reduce the risks for large to very large investments. Hence, validation and verification efforts of operational PV power plants with different design software are very important for the solar industry. This research paper presents the first specific validation and verification study of the Greenough River Solar Farm (12,68 MW<sub>DC</sub>, 10,00 MW<sub>AC</sub>, the first planned expansion to 40,00 MW<sub>AC</sub> in 2019) near Geraldton in Western Australia with the PVWatts Version 5 model of the National Renewable Energy Laboratory (NREL) System Advisor Model (SAM) Version 2017.9.5. The National Aeronautics and Space Administration (NASA) Modern-Era Retrospective Analysis for Research and Applications Version 2 (MERRA-2) datasets are used as a weather data source in this study. Location and resource, system design data and information on the Greenough River Solar Farm in this study are presumptions based upon publicly available information without any confirmation of power plant owners and operators. The Greenough River Solar Farm NREL SAM software models' are run on 2 different personal computers (PCs) with internet connection for years 2013 to 2017. The results of 6 simple simulations are compared with actual generation data for 2013 through 2017 with some statistical performance measures of the global unique forecast accuracy metrics pool in the Global Grid Prediction Systems (G<sup>2</sup>PS). The simulations average total time (milliseconds) are 64.1 and 77.9. The best model/actual accuracy measure is 101.9%. The minimum root mean square error (RMSE) is 254.142 MWh in 2013. The maximum RMSE is 414.931 MWh in 2014.

*Keywords:* SAM, System Advisor Model, Greenough River Solar Farm, Very Large Photovoltaic Solar Power Plants, NASA MERRA-2, Australia

#### 1. Introduction

Large Photovoltaic Solar Power Plants (LPVPPs) and Very Large Photovoltaic Solar Power Plants (VLPVPPs) are the

most feasible main items of 100% renewable power grids [1-3]. They have some major advantages such as ease of management, ease of operation and maintenance, economies of scale, and ease of design, engineering, procurement, and

construction. Their private investment models will be less difficult with some new investment model approaches such as openness to small-scale investment for ordinary people, investing in small to medium-sized companies and business opportunities, that most possibly create more jobs than large-sized companies and business opportunities.

LPVPP and VLPVPP design, engineering, procurement, and construction processes are almost the same as the utility-scale photovoltaic solar power plant (PVPP) design, engineering, procurement and construction processes. PV design tools are as important as the talents and experiences of designers and engineers in this long design spiral. There are many software alternatives for modelling PV systems. For instance; FreeGreenius [4], and System Advisor Model (SAM) [5]. Their models, algorithms, user interfaces, and user data and information requirements differ greatly (PV design tools). Hence, validation and verification research efforts of these software programs and their publications are worthwhile. This research study focuses on the NREL SAM software, that has been developed and used by many organizations and researchers such as the National Renewable Energy Laboratory (NREL), the University of Wisconsin (UW) for more than 10 years (see Table 1) [5-11]. The NREL SAM PVWatts V5 model in the latest NREL SAM software release (System Advisor Model Version 2017.9.5, 64 bit, updated to revision 3 SSC Version 184: Windows 64 bit Visual C++) is used in the current study [5-11]. This is the first main validation and verification research objective and motivation of the current study and its publication.

**Table 1.** Some Important System Advisor Model (SAM) Release [5]

Title	Date
Version 1.1	August 2007
Version 2.0	June 2008
Version 3.0	June 2009
Version 2009.10.2	October 2009
Version 2010.3.31	March 2010
Version 2011.5.4	May 2011
Version 2012.5.11	May 2012
Version 2013.9.20	September 2013
Version 2014.11.24 SSC Version 40	November 2014
Version 2015.1.30 SSC Version 41	January 2015
Version 2016.3.14 SSC Version 159	March 2016
Version 2017.1.17 SSC Version 170	January 2017
Version 2017.9.5 Revision 3, SSC Version 184	February 21, 2018

There are many PV panel technology developers such as First Solar, SunPower®, Yingli Green, SolarWorld, REC Group, Trina Solar, Suntech Power, Hanwha Q CELLS, JA Solar, Canadian Solar, Jinko Solar with several PV cell technologies such as monocrystalline silicon: Mono-Si or sc-Si (e.g. SunPower® X-Series, SunPower® E-Series, SunPower® P-Series, Yingli Green Panda Bifacial 60CF), multicrystalline (e.g. YGE 60 Cell Series 2), thin film

cadmium telluride: CdTe (e.g. First Solar Series 4™, First Solar Series 6™) with different cell efficiencies (i.e. 22.8%; 20.4%; 17.2%; 17.0%) in the photovoltaic solar power industry [12-22]. The PV panel technology developers' technical performances differ greatly. Hence, validation and verification research efforts of them on some software programs and their publications are worthwhile (PV panel technology developers). This research focuses on the First Solar Series 3 Black technology [12]. This is the second main validation and verification research objective and motivation of the current study and its publication.

There are many PVPPs installed with the First Solar PV panel technology. For instance, Mohammed Bin Rashid Al Maktoum Solar Park, 13 MW with 152.880 fixed tilt modules, in Dubai; Shams Maan Power Generation Solar Photovoltaic Power Plant, 52,5 MW with single axis trackers, in Jordan; Mahabugnagar Solar Park, 10 MW with 142.290 fixed tilt modules, in India; Hindupur Solar Park, 40 MW with 432.564 fixed tilt modules, in India; Otjozondjupa Solar Park, 5 MW with 52.000 single axis tracking modules, in Namibia; Topaz Solar Farm, 550 MW with 9.000.000 fixed tilt modules, in the U.S.A.; Copper Mountain Solar 1, 58 MW with 1.000.000 fixed tilt modules, in the U.S.A.; Agua Caliente Solar Project, 290 MW with 5.200.000 fixed tilt modules, in the U.S.A.; Luz del Norte, 141 MW with 1.700.000 fixed tilt modules, in Chile; Wellington Solar Farm, 180 MW with 511.630 single axis tracking modules, in New South Wales on the east coast of Australia; Greenough River Solar Farm, 10 MW with 152.000 fixed tilt modules, in Western Australia on the west coast of Australia [12]. The PVPPs' technical performances differ greatly in different regions of the World. Hence, validation and verification research efforts of them on some software programs and their publications are worthwhile (PVPPs). This research focuses on the Greenough River Solar Farm with 152.000 fixed tilt First Solar Series 3 Black modules [12, 23] in the south west of Western Australia. This solar farm has been included as one aspect of the previous publications regarding the potential for renewable energy in the south west of Western Australia [24, 25]. This is the third main validation and verification research objective and motivation of the current study and its publication.

There is an expansion plan of the Greenough River Solar Farm from 10 MW<sub>AC</sub> to 40 MW<sub>AC</sub>. The investment risks can be minimized with some meticulous research studies in every aspect of the Greenough River Solar Farm with its current 10 MW<sub>AC</sub> capacity. Moreover, the authors have an ongoing research study to design a VLPVPP in the same location of the Greenough River Solar Farm as its expansion to thousands of megawatts (e.g. 1000 MW<sub>AC</sub>, 2000 MW<sub>AC</sub>). The minimization of costs and risks and the maximization of electricity generation in this VLPVPP are crucial (start

investing with 10 MW<sub>AC</sub> and expand investing to 1000 MW<sub>AC</sub>, 2000 MW<sub>AC</sub> and so on). This is the fourth main validation and verification research objective and motivation of the current study and its publication.

In conclusion, as it might shortly be presented at the end of this section, there are 7 major validation and verification research objectives, motivations, and contributions of this study and its paper. These objectives, motivations, and contributions are basically its representation capability of a validation and verification effort for the PVWatts V5 model on the NREL SAM Version 2017.9.5 Revision 2, SSC Version 180, its representation capability of the First Solar Series 3 Black technology with a fixed tilt application in the south west of Western Australia (Greenough River Solar Farm), its contribution to the research and development efforts of VLPVPPs on a global scale, its contribution to the research and development efforts of the Global Grid Prediction Systems (G<sup>2</sup>PS), the Global Grid Electricity Demand Prediction System (G<sup>2</sup>EDPS), and the Global Grid Peak Power Prediction System (G<sup>2</sup>P<sup>3</sup>S), the Global Grid Generation Side Prediction Systems (G<sup>3</sup>SPS), the Global Grid Generation Side Electricity Generation Prediction System (G<sup>3</sup>SEGPS), the Global Grid Generation Side Peak Power Prediction System (G<sup>3</sup>SP<sup>3</sup>S), the Global Grid Generation Side Cost Prediction System (G<sup>3</sup>SCPS), the Global Grid Consumption Side Prediction Systems (G<sup>2</sup>CSPS), the Global Grid Consumption Side Electricity

Demand Prediction System (G<sup>2</sup>CSEDPS), the Global Grid Consumption Side Peak Power Prediction System (G<sup>2</sup>CSP<sup>3</sup>S), the Global Grid Consumption Side Price Prediction System (G<sup>2</sup>CSP<sup>2</sup>S) [26–29], and finally its contribution to the research efforts on climate change.

## 2. Greenough River Solar Farm

The Greenough River Solar Farm is a joint venture business model between Synergy and GE Energy Financial Services (General Electric). The Greenough River Solar Farm was constructed between April 2012 and July 2012. The first First Solar's CdTe thin-film PV modules were installed on 12 April 2012. The installation of all panels was finalized in July 2012. The commissioning of the Greenough River Solar Farm took one month (late July 2012 to late August 2012). It was officially opened in October 2012 [23].

### 2.1. Location

Greenough River Solar Farm (10,00 MW, Planned Expansion: 40,00 MW) on Google Earth Pro 7.1.5.1557 [30] are as follows (open Greenough River Solar Farm.kmz) (Figure 1):

Latitude & Longitude: 28°54'22.71"S, 115° 6'54.59"E; 28°54'6.38"S, 115° 6'54.80"E; 28°54'6.14"S, 115° 6'28.51"E; 28°54'11.90"S, 115° 6'28.47"E; 28°54'11.92"S, 115° 6'30.42"E; 28°54'22.25"S, 115° 6'30.49"E.



**Figure 1.** Greenough River Solar Farm location (10,00 MW<sub>AC</sub>, 12,68 MW<sub>DC</sub>, Planned expansion: 40,00 MW) in yellow color, (according to the literature review) (generated by Google Earth Pro 7.1.5.1557 [30], Paint.NET.4.0.16 [31]).

**2.2. Weather file resource (Model)**

The NREL SAM requires a weather data file to describe the renewable energy resource and weather conditions at a project location. The weather files used in this analysis have been derived from the National Aeronautics and Space Administration (NASA) Modern-Era Retrospective Analysis for Research and Applications, Version 2 (MERRA-2) datasets [32]. These datasets potentially provide a suitable source of worldwide weather data for the NREL SAM, especially for those countries, that do not have a more accurate source of weather data.

The NASA MERRA-2 provides data beginning in 1980 with worldwide coverage. The datasets provide a spatial resolution of about 55 kilometers in latitude (0.5 degree of latitude x 0.625 degree of longitude) [32]. The datasets provide a potential source for weather data covering the earth from 85 degrees north to 85 degrees south [32].


The NREL SAM weather files contain data for a full year (8.760 hours; excluding 29 February). The NASA MERRA-2 datasets are daily, requiring files for a full year to be downloaded. A Python program, getmerra2.py, has been created to simplify downloading the NASA MERRA-2 files. The program is available for download in either source format, or in a package suitable for execution under Windows [33]. Two time averaged two-dimensional NASA MERRA-2 datasets – tavg1\_2d\_slv\_Nx Single Level Diagnostics and tavg1\_2d\_rad\_Nx Radiation Diagnostics provide hourly data, that can be used to create NREL SAM weather files [34]. The tavg1\_2d\_slv\_Nx dataset provides hourly temperature and pressure data (also wind data at 50 meter height, which makes it suitable for input to the NREL SAM wind model). The tavg1\_2d\_rad\_Nx dataset provides surface incoming shortwave flux (SWGDN variable) which can be used as a proxy for the Global Horizontal Insolation (GHI) [35,36]. Using routines from the NREL, it is possible to calculate the Direct Normal Insolation (DNI) [37] and the

Direct Horizontal Insolation (DHI) [38] from the GHI. This enables solar weather files to be created for input into the various NREL SAM solar models, specifically pvwattsV5. A Python program, makeweatherfiles.py, has been created to enable the NREL SAM weather files to be created from downloaded the NASA MERRA-2 files. It is available for download in the same way as getmerra2.py.



The area of the appropriate NASA MERRA-2 cell of the Greenough River Solar Farm is presented in Figure 2. The weather file information is presented on the NREL SAM Version 2017.9.5 as shown in Figure 3 (solar\_weather\_29.0000\_115.0000\_2013.smw: 2013, solar\_weather\_29.0000\_115.0000\_2014.smw: 2014, solar\_weather\_29.0000\_115.0000\_2015.smw: 2015, solar\_weather\_29.0000\_115.0000\_2016.smw: 2016, solar\_weather\_29.0000\_115.0000\_2017.smw: 2017).





**Figure 2.** The area of the appropriate NASA MERRA-2 cell for the solar farm and the other solar farm's location within the cell. The cell is approximately 55 kilometers by 60 kilometers (generated by Google Earth Pro 7.1.5.1557 [30]).





2014



2015



2016






Figure 3. The NASA MERRA-2 Greenough River Solar Farm 2013-2017 global irradiance-GHI ( $W/m^2$ ) (left), wind velocity (m/s) (right).

### 2.3. System parameters

The direct current (DC) capacity of the Greenough River Solar Farm is 12,68  $MW_{DC}$  [39]. Its alternating current (AC) capacity is 10,00  $MW_{AC}$  [12]. Therefore, the DC:AC ratio is calculated as 1.268. There are total 152.000 installed First Solar Series 3 PV modules (panels) with a ground coverage of approximately 80 hectares ( $0.8 \text{ km}^2$ ) [12, 39] (Table 2). The exact total number of panels cannot be found in any data and information sources, but it should be nearly 152.000 (e.g. 152.800, 152.000, 150.000) [12, 23, 39]. The FS Series 3 thin-film PV modules with cadmium telluride (CdTe) semiconductors have 5 different models with different panel efficiencies (FS-382: 11.50%, FS-385: 11.80%, FS-387: 12.20%, FS-390: 12.50%, FS-392: 12.80%) [40]. The FS Series 3 thin-film PV modules were introduced to the market

in late 2013 [41]. There are SMA Sunny Central 720CP central inverters at the Greenough River Solar Farm [42, 43]. The SMA 720 kW central inverter efficiencies are found as 98.60%; 98.40%; 98.00% for the maximum efficiency, the European weighted efficiency and the CEC efficiency in the catalog of the SMA Sunny Central 720CP-US [44]. The inverters have been de-rated to 648 kW for system management reasons by giving an efficiency value of 90%. The model on the PVWatts V5, NREL SAM Version 2017.9.5 Revision 2 and actual system parameters are given in Table 2 and Table 3. As a consequence, there is a model on the PVWatts V5, NREL SAM Version 2017.9.5 Revision 2 and actual (real life) observation major mismatch in this section, due to the system configuration and the equipment properties.

Table 2. System Parameters of the Greenough River Solar Farm

SAM Model Parameters	SAM Model Value	SAM Model Unit	Actual	Core References
System nameplate size	12.680	kWdc	12.68 $MW_{DC}$	[Craig Carter, personal communication]
Module type	Thin film	-	FS Series 3 thin-film PV modules	[12, 39]
DC to AC ratio	<sup>a</sup> 1.268	-	-	
Inverter efficiency	<sup>b</sup> 90%	-	SMA Sunny Central 720CP and System management	[42, 43]

<sup>a</sup>DC to AC ratio: Case According To Personal Communication is 1.223, others are 1.268; <sup>b</sup>Inverter efficiency: The SMA 720 kW central inverters' efficiencies are found as 98.60%; 98.40%; 98.00% for the maximum efficiency, the European weighted efficiency and the CEC efficiency in the catalog of the SMA Sunny Central 720CP-US [44]. For system management reasons the inverters have been de-rated to 648 kW, giving an efficiency value of 90%.

Table 3. Module type

SAM Module Type	SAM Approximate Nominal Efficiency	SAM Module Cover	SAM Temperature Coefficient of Power
Standard (crystalline Silicon)	15%	Glass	-0.47 %/°C
Premium (crystalline Silicon)	19%	Anti-reflective	-0.35 %/°C
<sup>a,b</sup> Thin film	10%	Glass	-0.20 %/°C

<sup>a</sup>Thin-film: "The thin film option assumes a low efficiency (~11%), and a significantly lower temperature coefficient, which is representative of most installed thin film modules as of 2013. It is important to note that less common thin film module technologies may have quite different temperature coefficients than the default." [11]. <sup>b</sup>FS Series 3 thin-film PV module efficiency: 11.5%-12.8% [40].

## 2.4. Orientation

The Greenough River Solar Farm in its current capacity and system configuration is a ground mount fixed tilt facility [12, 43]. Due to the strong winds experienced in the area a lower than the normal tilt angle of 20 degrees is chosen for the installation (personal communication).

Some important design elements on the PVWatts V5, NREL SAM Version 2017.9.5 Revision 2 about the orientation are as follows:

- "The array's tilt angle in degrees from horizontal, where zero degrees is horizontal, and 90 degrees is vertical and

facing the equator (in both the southern and northern hemispheres." [45]

- "Azimuth, degrees: For systems north of the equator, a typical azimuth value would be 180 degrees. For systems south of the equator, a typical value would be 0 degrees." [45]

The model on the PVWatts V5, NREL SAM Version 2017.9.5 Revision 2 and actual (real life) system parameters are presented in Table 4. There is a high possibility of the model and actual (real life) observation major mismatch in the orientation.

**Table 4.** Orientation Parameters.


Model Parameters	Model Value	Model Unit	Actual	References
Array type	Fixed open rack	-	Ground Mount Fixed Tilt	[12,43]
Tilt	20°	degrees	20°	
Azimuth	0°	degrees	0°	

## 2.5. Losses

The system losses of the PVWatts Version 5 model of the NREL SAM Version 2017.9.5 are soiling loss, shading loss, snow loss, mismatch loss, wiring loss, connections loss, light-induced degradation loss, nameplate rating loss, age loss, and availability loss. The short explanations of these system losses are as follows:

- Soiling Loss: "due to dust, dirt, and other foreign matter on the surface of the PV module that prevent solar radiation from reaching the cells" [45]

- Shading Loss: "Reduction in the incident solar radiation from shadows caused by objects near the array such as buildings or trees, or by self-shading for fixed arrays or arrays with two-axis tracking. For fixed arrays or arrays with two-axis tracking that consist of multiple rows of modules, you can use the table below to choose a loss percentage to represent self-shading (losses that occur when modules in one row cause shadows on those in an adjacent row). Industry practice is to optimize the use of space by configuring the PV system for a GCR that corresponds to a shading derate factor of 0.975 (2.5% loss)." (see Figure 4) [45]



**Figure 4.** Shading derate factor versus ground cover ratio (GCR) for different tracking options and tilt angles (drawn, redrawn, generated and regenerated based on source PowerLight Corp. on [45] with Paint.NET.4.0.16 [31]).

- Snow Loss: "Reduction in the system's annual output due to snow covering the array." [45]
- Mismatch Loss: "Electrical losses due to slight differences caused by manufacturing imperfections between modules in the array that cause the modules to have slightly different current-voltage characteristics." [45]
- Wiring Loss: "Resistive losses in the DC and AC wires connecting modules, inverters, and other parts of the system." [45]
- Connections Loss: "Resistive losses in electrical connectors in the system." [45]
- Light-Induced Degradation Loss: "Effect of the reduction in the array's power during the first few months of its operation caused by light-induced degradation of photovoltaic cells." [45]
- Nameplate Rating Loss: "Nameplate rating loss accounts for the accuracy of the manufacturer's nameplate rating. Field measurements of the electrical characteristics of photovoltaic modules in the array may show that they differ from their nameplate rating." [45]
- Age Loss: "Effect of weathering of the photovoltaic modules on the array's performance over time" [45]
- Availability Loss: "Reduction in the system's output cause by scheduled and unscheduled system shutdown for maintenance, grid outages, and other operational factors." [45]

The soiling loss value of the Greenough River Solar Farm is determined based on some information on some specific documents such as "soiling: <math>\lt; 3\%/yr</math>", and "monthly average actual measured soiling 0.31%" [46, 47]. This loss is mainly a PV panel technology, PV power plant site and PV power plant design specific loss.

The shading loss value of the Greenough River Solar Farm is determined in accordance with the SAM help manual ("Shading Loss" and Figure 4). The ground coverage ratio (GCR) is estimated based on the measurements on the Google Earth Pro 7.1.5.1557 in accordance with its description ( $GCR = A/B =$  approximately  $2.20\text{ m} / 5.20\text{ m}$  measurement = 0.4231, actual  $A = 1.2\text{ m}$ , measurement accuracy:  $1.20\text{ m} / 2.20\text{ m} = 54,54\%$ ) [48, 49]. Hence, the shading derate factor is read on the fixed 20 degree tilt curve from Figure 4 as 0,99 for the GCR of 0.4231. This loss is mainly a PV panel technology, PV power plant site and PV power plant design specific loss.

The snow loss value of the Greenough River Solar Farm is determined according to the climatic conditions of the precipitation and the snowfall of Geraldton and Mullewa in Western Australia [50-51]. This loss is mainly a PV panel technology, PV power plant site and PV power plant design specific loss.

The mismatch loss value of the Greenough River Solar Farm is determined based on some information on some specific documents such as "1.0 % First Solar module performance guidance" [47]. This loss is mainly a PV panel technology specific loss.

The wiring loss value of the Greenough River Solar Farm is determined according to the general PV literature and on some information on some specific documents "DC Wiring derating factor: 0.98" and "AC Wiring derating factor: 0.99" [47, 52-54]. This loss is mainly a PV power plant site and PV power plant design specific loss.

The connections loss value of the Greenough River Solar Farm is determined according to the general PV literature and on some information on some specific documents [47, 52-54]. This loss is mainly a PV power plant site and PV power plant design specific loss.

The light-induced degradation loss value of the Greenough River Solar Farm is determined according to the general PV literature and the catalogs of the First Solar Series 3 PV modules [41, 55-60]. This loss is mainly a PV panel technology specific loss.

The nameplate rating loss value of the Greenough River Solar Farm is determined according to the general PV literature and on some information on some specific documents [42, 60, 61]. This loss is mainly a PV panel technology specific loss.

The age loss value of the Greenough River Solar Farm is determined according to the general PV literature and the catalogs of the First Solar Series 3 PV modules [41, 55-60].

The availability rating loss value of the Greenough River Solar Farm is determined according to the Verve Energy documents "Greenough River Solar Farm Pty Ltd, a joint venture partnership between Verve Energy and GE Energy Financial Services", and "Plant availability has been > than 99%" [42, 61]. This loss is mainly a PV panel technology, PV power plant site, PV power plant design and all other issues specific loss.

There are 6 models related to the losses on the PVWatts V5, NREL SAM Version 2017.9.5 Revision 2 in this study. These 6 models are the "SAM Default Value Case (%)", the "Most Possible Value Case (%)", the "Reasonable Minimum Value Case (%)", the "Reasonable Maximum Value Case (%)", the "Case More Or Less According To Personal Communication (%)", and the "Case According To Total System Losses (%)". These 6 models and the losses on the PVWatts V5, NREL SAM Version 2017.9.5 Revision 2 are presented in Table 5. The models and actual (real life) observations major mismatch is expected in the losses issues.

### 3. Results and Discussion

The annual output data of the Greenough River Solar Farm is 22.000 MWh for the first 12 months period [42]. The annual output data of the Greenough River Solar Farm between 2013 and 2017 are gathered from the official records [63].

#### 3.1. Actual Generation

The generation data in the form of Supervisory Control and Data Acquisition (SCADA) generation quantity is publicly available for all generation units in the South West Interconnected System (SWIS) of south-west Western

Australia. The data is available as monthly comma separated variable (\*.csv) files for half hourly trading intervals [64]. The data for the Greenough River Solar Farm is identified with a facility code of GREENOUGH\_RIVER\_PV1. The generation data has been aggregated into monthly figures with the exception of February 29, 2012 and 2016 as the NREL SAM works on a 365 day (8.760 hours).

**Table 5. PVWATTS SAM Losses**

Losses	SAM Default Value Case (%)	Most Possible Value Case (%)	Reasonable Minimum Value Case (%)	Reasonable Maximum Value Case (%)	Case More or Less According to Personal Communication (%)	Case According to Total System Losses (%)	Core References
Soiling	2	3	2	4	3	-	[46,47]
<sup>a</sup> Shading	<sup>a</sup> 3	0	<sup>a</sup> 1	<sup>a</sup> 4	0	-	
Snow	0	0	0	0	0	-	[50-51]
Mismatch	2	1	0.5	3	0	-	[47]
<sup>a</sup> Wiring	<sup>a</sup> 2	<sup>a</sup> 2	<sup>a</sup> 1	<sup>a</sup> 4	2	-	[47,53-55]
<sup>a</sup> Connections	<sup>a</sup> 0.5	<sup>a</sup> 0.5	<sup>a</sup> 0.3	<sup>a</sup> 1	0.5	-	[47,53-55]
<sup>a</sup> Light-Induced Degradation	1.5	0.9	0.5	4	0	-	[41,56-61]
<sup>a</sup> Nameplate Rating	<sup>a</sup> 1	<sup>a</sup> 2	<sup>a</sup> 0.5	<sup>a</sup> 3	0	-	[41,61,62]
<sup>a</sup> Age	<sup>a</sup> 0	<sup>a</sup> 2	<sup>a</sup> 1	<sup>a</sup> 3.5	0	-	[41,56-61]
<sup>a</sup> Availability	<sup>a</sup> 3	<sup>a</sup> 1	<sup>a</sup> 0	<sup>a</sup> 5	1	-	[42,63]
<sup>b,c</sup> Total system losses	14.08	11.77	6.63	27.47	6.36	15	

<sup>a</sup>Losses: These inputs are preliminary indicative values for finding the total system losses. They could not be crosschecked and confirmed yet. The readers should not use these losses in their scientific, engineering and commercial studies, before any further research studies presented in the literature. <sup>b</sup>Total system losses =  $100\% \times \{1 - [(1 - \text{Soiling} \div 100\%) \times (1 - \text{Shading} \div 100\%) \times (1 - \text{Snow} \div 100\%) \times (1 - \text{Mismatch} \div 100\%) \times (1 - \text{Wiring} \div 100\%) \times (1 - \text{Connections} \div 100\%) \times (1 - \text{Light-induced degradation} \div 100\%) \times (1 - \text{Nameplate} \div 100\%) \times (1 - \text{Age} \div 100\%) \times (1 - \text{Availability} \div 100\%)]\}$ , <sup>c</sup>Total system losses: The readers may use the value of this total system losses input in their scientific, engineering and commercial analysis in accordance with the assumptions, inputs, results, and findings of this study.

#### 3.2. Simulations

There is a single NREL SAM Version 2017.9.5 Revision 2, SSC Version 180 file with 6 model sheets (Greenough River Solar Farm.sam) for each year in this study (totally 5 files 2013-2017). The sheets and acronyms of the NREL SAM Version 2017.9.5 Revision 2, SSC Version 180 file are SAMD for the "SAM Default Value Case (%)", MP for the "Most Possible Value Case (%)", RMIN for the "Reasonable Minimum Value Case (%)", RMAX for the "Reasonable Maximum Value Case (%)", PC for the "Case More Or Less According To Personal Communication (%)" and TSL for the "Case According To Total System Losses (%)". There are 2 different hardware options of the current simulations in this study. These are a Windows personal computer (PC) (Windows 10 Pro, Intel(R) Core(TM) i5 CPU 650 @ 3.20 GHz, 6,00 GB RAM) and a Linux personal computer (PC) (Ubuntu 17.10, AMD(R) A9-9430 Radeon r5, 5 compute

cores 2c+3g×2@3.20 GHz, 7.8Gb RAM). The simulation report summaries are presented in Table 6, Table 7, Table 8.

#### 3.3. SAM results and actual generation comparisons

In comparing model outputs from the NREL SAM to actual generation data one needs to take into account the actual system design and implementation decisions that are not covered by the model. In the case of the Greenough River Solar Farm, the system has a 10,00 MW export limit at the point of connection to the grid. However, to guarantee energy production the number of modules has been adjusted. To ensure the export limit is not exceeded the inverters have been "de-rated" to about 90% of their capacity. To cater for this in the modeling the SAM models have been run with an inverter efficiency of 90,00% [64]. Under this important circumstance, the simulation results are gathered and compared with only a few forecast accuracy metrics (i.e. scale-dependent errors: forecast errors ( $e_t$ ), absolute forecast errors ( $|e_t|$ ), Mean Absolute Error (MAE), Geometric Mean

**Table 6.** PVWATTS SAM Simulation Report of PC Windows 10 Pro, Intel(R) Core(TM) i5 CPU 650 @ 3.20 GHZ, 6,00 GB RAM with internet connection

Model	Total time (ms)	SSC time (ms)	Errors	Warnings	Notices	Annual energy (year 1) (kWh)	Capacity factor (year 1) (%)	Energy yield (year 1) (kWh/kW)	
2013	<sup>a</sup> SAMD	94	93	0	0	0	22.626.782	20.4	1.784
	<sup>b</sup> MP	68	67	0	0	0	23.157.658	20.8	1.826
	<sup>c</sup> RMIN	63	62	0	0	0	24.245.572	21.8	1.912
	<sup>d</sup> RMAX	62	62	0	0	0	19.137.884	17.2	1.509
	<sup>e</sup> PC	62	62	0	0	0	24.479.782	22.0	1.931
	<sup>f</sup> TSL	61	60	0	0	0	22.403.222	20.2	1.767
2014	<sup>a</sup> SAMD	68	67	0	0	0	22.493.822	20.3	1.774
	<sup>b</sup> MP	66	65	0	0	0	23.016.676	20.7	1.815
	<sup>c</sup> RMIN	63	62	0	0	0	24.092.986	21.7	1.900
	<sup>d</sup> RMAX	68	67	0	0	0	19.024.892	17.1	1.500
	<sup>e</sup> PC	63	62	0	0	0	24.328.382	21.9	1.919
	<sup>f</sup> TSL	62	61	0	0	0	22.272.894	20.1	1.757
2015	<sup>a</sup> SAMD	65	64	0	0	0	22.529.162	20.3	1.777
	<sup>b</sup> MP	62	61	0	0	0	23.069.198	20.8	1.819
	<sup>c</sup> RMIN	61	60	0	0	0	24.168.974	21.8	1.906
	<sup>d</sup> RMAX	60	59	0	0	0	19.041.522	17.1	1.502
	<sup>e</sup> PC	62	60	0	0	0	24.397.256	22.0	1.924
	<sup>f</sup> TSL	63	62	0	0	0	22.302.290	20.1	1.759
2016	<sup>a</sup> SAMD	63	62	0	0	0	22.511.598	20.3	1.775
	<sup>b</sup> MP	61	60	0	0	0	23.032.192	20.7	1.816
	<sup>c</sup> RMIN	60	59	0	0	0	24.107.520	21.7	1.901
	<sup>d</sup> RMAX	64	63	0	0	0	19.054.910	17.2	1.503
	<sup>e</sup> PC	62	61	0	0	0	24.346.238	21.9	1.920
	<sup>f</sup> TSL	62	61	0	0	0	22.293.418	20.1	1.758
2017	<sup>a</sup> SAMD	61	60	0	0	0	22.773.060	20.5	1.796
	<sup>b</sup> MP	66	65	0	0	0	23.313.812	21.0	1.839
	<sup>c</sup> RMIN	63	62	0	0	0	24.416.984	22.0	1.926
	<sup>d</sup> RMAX	64	63	0	0	0	19.257.092	17.3	1.519
	<sup>e</sup> PC	64	63	0	0	0	24.649.918	22.2	1.944
	<sup>f</sup> TSL	60	60	0	0	0	22.545.862	20.3	1.778


**Table 7.** PVWATTS SAM Simulation Report of PC Ubuntu 17.10. AMD(R) A9-9430 Radeon r5. 5 compute cores 2c+3g × 2 @ 3.20 GHZ. 7.8Gb RAM with internet connection

Model	Total time (ms)	SSC time (ms)	Errors	Warnings	Notices	Annual energy (year 1) (kWh)	Capacity factor (year 1) (%)	Energy yield (year 1) (kWh/kW)	
2013	<sup>a</sup> SAMD	80	79	0	0	0	22.626.782	20.4	1.784
	<sup>b</sup> MP	75	73	0	0	0	23.157.658	20.8	1.826
	<sup>c</sup> RMIN	79	77	0	0	0	24.245.572	21.8	1.912
	<sup>d</sup> RMAX	73	72	0	0	0	19.137.884	17.2	1.509
	<sup>e</sup> PC	75	73	0	0	0	24.479.782	22.0	1.931
	<sup>f</sup> TSL	72	71	0	0	0	22.403.222	20.2	1.767
2014	<sup>a</sup> SAMD	77	75	0	0	0	22.493.822	20.3	1.774
	<sup>b</sup> MP	77	75	0	0	0	23.016.676	20.7	1.815
	<sup>c</sup> RMIN	78	76	0	0	0	24.092.986	21.7	1.900
	<sup>d</sup> RMAX	76	73	0	0	0	19.024.892	17.1	1.500
	<sup>e</sup> PC	80	78	0	0	0	24.328.382	21.9	1.919
	<sup>f</sup> TSL	81	78	0	0	0	22.272.894	20.1	1.757
2015	<sup>a</sup> SAMD	73	71	0	0	0	22.529.162	20.3	1.777
	<sup>b</sup> MP	77	75	0	0	0	23.069.198	20.8	1.819
	<sup>c</sup> RMIN	79	77	0	0	0	24.168.974	21.8	1.906
	<sup>d</sup> RMAX	72	71	0	0	0	19.041.522	17.1	1.502
	<sup>e</sup> PC	76	75	0	0	0	24.397.256	22.0	1.924
	<sup>f</sup> TSL	73	72	0	0	0	22.302.290	20.1	1.759
2016	<sup>a</sup> SAMD	79 (94)	77 (92)	0	0	0	22.511.598	20.3	1.775
	<sup>b</sup> MP	76	74	0	0	0	23.032.192	20.7	1.816
	<sup>c</sup> RMIN	72	71	0	0	0	24.107.520	21.7	1.901
	<sup>d</sup> RMAX	79	77	0	0	0	19.054.910	17.2	1.503
	<sup>e</sup> PC	82	80	0	0	0	24.346.238	21.9	1.920
	<sup>f</sup> TSL	77	76	0	0	0	22.293.418	20.1	1.758
2017	<sup>a</sup> SAMD	74 (98)	73 (96)	0	0	0	22.773.060	20.5	1.796
	<sup>b</sup> MP	78	76	0	0	0	23.313.812	21.0	1.839
	<sup>c</sup> RMIN	75	73	0	0	0	24.416.984	22.0	1.926
	<sup>d</sup> RMAX	78	76	0	0	0	19.257.092	17.3	1.519
	<sup>e</sup> PC	76	74	0	0	0	24.649.918	22.2	1.944
	<sup>f</sup> TSL	78	77	0	0	0	22.545.862	20.3	1.778

<sup>a</sup>SAMD: SAM Default Value Case (%). <sup>b</sup>MP: Most Possible Value Case (%). <sup>c</sup>RMIN: Reasonable Minimum Value Case (%). <sup>d</sup>RMAX: Reasonable Maximum Value Case (%). <sup>e</sup>PC: Case More Or Less According To Personal Communication (%). <sup>f</sup>TSL: Case According To Total System Losses (%).

**Table 8.** PVWATTS SAM Simulation Comparison

Hardware Configurations	Average Total time	Average SSC time	Maximum Total time	Maximum SSC time
PC Windows 10 Pro. Intel(R) Core(TM) i5 CPU 650 @ 3.20 GHZ. 6.00 GB RAM with internet connection	64.1 ms	63.2 ms	94 ms	93 ms
PC Ubuntu 17.10. AMD(R) A9-9430 radeon r5. 5 compute cores 2c+3g × 2 @ 3.20 GHz. 7.8Gb RAM	77.9 ms	76.1 ms	98 ms	96 ms
Performance Ratio (1 <sup>st</sup> PC/2 <sup>nd</sup> PC)	82.29%	83.05%	95.92%	96.88%



**Figure 5.** Greenough River Solar Farm Monthly SAM Results and Actual Generation Comparisons

Absolute Error (GMAE). Mean Square Error (MSE). Root Mean Square Error (RMSE); percentage errors: Absolute Percentage Errors (APE). Minimum Absolute Percentage Error (MinAP). Maximum Absolute Percentage Error (MAP). Mean Absolute Percentage Error (MAPE). Symmetric MAPE (SMAPE); relative errors: Relative Error (r\_t). Median Relative Absolute Error (MdRAE). Geometric Mean Relative Absolute Error (GMRAE)) available in the literature and global unique forecast accuracy metrics pool of the Global Grid Prediction Systems (G2PS) (see [2. 26-29. 65-69]).

The SAMD, MP, RMIN, RMAX, PC, TSL vs. actual generation comparisons are presented in Figure 5. The whole data set "model/actual" values for SAMD, MP, RMIN, RMAX, PC, and TSL are respectively 102.9%, 105.3%, 110.3%, 87.0%, 111.3%, and 101.9%. In other words, the whole data set "model/actual" value differences are 2.9%, 5.3%, 10.3%, -13.0%, 11.3%, and 1.9%. Five models (SAMD, MP, RMIN, PC, TSL) have positive "model/actual" value deviations (bias). They overestimate the generation of the Greenough River Solar Farm. One model (RMAX) has negative "model/actual" value deviation (bias).

The TSL simulation and actual generation comparison of the Greenough River Solar Farm is given for a few forecast accuracy metrics in this paragraph (see Table 9 and Table 10). Others may be reviewed in the electronic supplementary

files. The maximum forecast error ( $e_t$ ) is observed in January 2014 (319,11 MWh). The minimum  $e_t$  is observed in February 2013 (1,77 MWh). The absolute maximum forecast error ( $|e_t|$ ) is observed in January 2014 (319,11 MWh). The absolute minimum  $|e_t|$  is observed in February 2013 (1,77 MWh). The minimum mean absolute error (MAE) is 55,994 MWh in 2013. The maximum MAE is 88,479 MWh in 2017. The minimum geometric mean absolute error (GMAE) is 33,475 MWh in 2013. The maximum GMAE is 58,692 MWh in 2016. The minimum mean square error (MSE) is 64.588,220 MWh in 2013. The maximum MSE is 172.167,524 MWh in 2014. The minimum root mean square error (RMSE) is 254,142 MWh in 2013. The maximum RMSE is 414,931 MWh in 2014. The minimum absolute percentage error (MinAP) is 1.7775 in 2013. The maximum MinAP is 15,135 in 2016. The minimum maximum absolute percentage error (MAP) is 0.085 in 2013. The maximum MAP is 0.158 in 2014. The minimum mean absolute percentage error (MAPE) is 0.033 in 2013. The maximum MAPE is 0.049 in 2014 and 2016. The maximum model/actual is 17.4% in January 2016. The minimum model/actual is -10.7% in July 2014. The absolute minimum model/actual is 0.1% in February 2013. May 2017. The absolute maximum model/actual is 17.4% in January 2016. There is no seasonal prediction accuracy observed in this study.

**Table 9.** Greenough River PVWATTS SAM Simulations Forecast Accuracy

Months	2013			2014			2015		
	$e_t$	$APE_t$	Model/Actual	$e_t$	$APE_t$	Model/Actual	$e_t$	$APE_t$	Model/Actual
January	30.52	0.014	1.01	319.12	0.158	1.16	3.36	0.001	1.00
February	1.78	0.001	1.00	2.84	0.001	1.00	100.16	0.054	1.05
March	8.60	0.004	1.00	73.56	0.037	0.96	181.12	0.098	1.10
April	141.36	0.085	0.91	27.46	0.016	1.02	3.27	0.002	1.00
May	118.80	0.078	0.92	51.44	0.038	0.96	27.19	0.016	0.98
June	24.20	0.016	0.98	101.46	0.069	0.93	74.63	0.058	1.06
July	126.54	0.079	0.92	160.98	0.107	0.89	11.04	0.008	0.99
August	20.94	0.013	0.99	20.38	0.012	0.99	48.24	0.031	0.97
September	92.00	0.054	1.05	88.01	0.052	1.05	19.10	0.009	0.99
October	44.08	0.019	1.02	108.60	0.052	1.05	99.83	0.049	1.05
November	36.43	0.017	0.98	67.44	0.031	1.03	108.19	0.053	1.05
December	26.69	0.011	1.01	28.33	0.012	1.01	126.79	0.057	1.06
Total	671.93	0.391	0.99	1.049.62	0.586	1.01	802.91	0.438	1.03

**Table 10.** Greenough River PVWATTS SAM Simulations Forecast Accuracy (continued)

Months	2016			2017		
	$e_t$	$APE_t$	Model/Actual	$e_t$	$APE_t$	Model/Actual
January	67.67	0.035	1.03	60.53	0.028	1.03
February	20.71	0.010	1.01	102.54	0.055	1.06
March	29.36	0.015	0.99	115.97	0.058	1.06
April	69.81	0.045	0.96	85.04	0.045	0.95
May	159.16	0.114	1.11	2.14	0.001	1.00
June	190.02	0.174	1.17	2.38	0.002	1.00
July	26.18	0.019	0.98	20.35	0.016	0.98
August	15.14	0.010	0.99	36.89	0.023	1.02
September	90.52	0.048	1.05	161.07	0.098	1.10
October	125.10	0.058	1.06	164.45	0.079	1.08
November	69.02	0.031	1.03	155.91	0.076	1.08
December	62.11	0.026	1.03	154.46	0.072	1.07
Total	924.79	0.585	1.03	8.043.42	2.212	1.01

**Table 11.** Greenough River PVWATTS SAM Simulations Forecast Accuracy (annual)


Years	MAE	GMAE	MSE	RMSE	MAP	SMAPE	MAPE
2013	55.994	33.475	64.588.220	254.142	0.085	1.7%	0.033
2014	87.468	53.684	172.167.524	414.931	0.158	2.4%	0.049
2015	66.909	36.519	89.725.959	299.543	0.098	1.8%	0.037
2016	77.066	58.692	105.561.063	324.902	0.174	2.3%	0.049
2017	88.479	47.667	137.800.827	371.215	0.098	2.2%	0.046

Table 11 summarizes the comparisons between actual generation and calculated generation and the degree of “fit” between both datasets on an hourly basis. Overall, there is a strong correlation between both datasets. The average correlation for the full datasets is 0.964. Removing all figures where both sets of data are zero, that is, removing non-generating hours, gives an average correlation of 0.928 ( $R^2$ : 0.860), which is still very strong. The average calculated

generation is also of the same magnitude as the actual generation. Figure 6 is a scatter plot for 2017, showing the reasonably good fit between calculated and actual generation. These figures suggest the dataset and usage of the NREL SAM models are useful in evaluating the potential for PV generation in the south west of Western Australia (region nearby the Greenough River Solar Farm).

**Table 12.** Actual and Calculated Generation - Greenough River Solar Farm

Year	Actual (MWh)	CF	Calc (MWh)	Calc CF	Corr	Calc/Actual	Avg. gen. hours/day	Corr.gen hours	$R^2$
2013	22.667,836	0.259	22.403,196	0.256	0.968	98.8%	12.9	0.939	0.881
2014	22.044,605	0.252	22.272,910	0.254	0.958	101.0%	12.3	0.914	0.836
2015	21.717,233	0.248	22.302,285	0.255	0.963	102.7%	12.3	0.923	0.853
2016	21.649,592	0.247	22.293,418	0.254	0.964	103.0%	12.3	0.926	0.858
2017	21.694,898	0.248	22.545,864	0.257	0.968	103.9%	12.3	0.935	0.874
Total	109.774,164		111.817,673		0.964	101.9%		0.928	0.860

**Figure 6.** Greenough River Solar Farm 2017 SAM Results and Actual Generation Linear Fitting

#### 4. Conclusions and Future Research Studies

This initial research study presents the first validation and verification effort of the PVWatts V5 model on the NREL SAM Version 2017.9.5 Revision 2, SSC Version 180 performance models at the Greenough River Solar Farm like SEGS VI, Topaz Solar Farm and Solar Star Projects [2, 68]. There are some strengths and weaknesses of this research study. Some of the strengths are related to the information gathered for the modelling during this research study and using one of the most applied modelling tools and algorithms.

Some of the weaknesses are related to the unavailable field losses data such as mismatch (%) and the weather source data.

The novelty of the obtained results in this research study is its presentation of the simulation and actual PVPP generation values and the values of the forecast accuracy metrics not only on an annual basis, but also the whole operational period of a PVPP with its uniqueness of being the first validation and verification research effort of the PVWatts V5 model on the NREL SAM Version 2017.9.5 Revision 2, SSC Version 180 performance models at the Greenough River Solar Farm (the first research study), and also being the first validation and verification research effort of a PVPP in the south west of Western Australia region of the World (the first research study) with different expert evaluations on the system losses by the first usage of NASA MERRA-2 dataset (the first research study) on two different PCs (the first research study). The best simulation performed absolute model/actual model is TSL with a deviation of 1.9%, which is almost excellent forecast estimation.

Also, an interesting contribution of this research study is in the research, development, demonstration and deployment (RD<sup>3</sup>) efforts of VLPVPP on the World and also the G<sup>2</sup>PS, the G<sup>2</sup>EDPS, the G<sup>2</sup>P<sup>3</sup>S, the G<sup>3</sup>SPS, the G<sup>3</sup>SEGPS, the G<sup>3</sup>SP<sup>3</sup>S, the G<sup>3</sup>SCPS, the G<sup>2</sup>CSPS, the G<sup>2</sup>CSEDPS, the G<sup>2</sup>CSP<sup>3</sup>S, the G<sup>2</sup>CSP<sup>2</sup>S [36-29, 65, 69].

In the next research studies, the system management and configuration and also the hourly generation data of the Greenough River Solar Farm will be tried to be found from the operators, and owners, the planned expansion (40 MW) power plant will be modelled and future generation figures will be forecast or projected to guide the investors. The detailed photovoltaic (PV) model in the latest NREL SAM version will be studied and run to compare this model. The

core aim of all of these efforts is for researching and developing an autonomous and automatic design tool on Geographic Information Systems (GIS) by an artificial intelligence approach at the end.

#### Acknowledgment

The authors would sincerely like to express their thankfulness to Craig Carter, and Andreas Wade for guidance and help.

Nomenclature	
AC: Alternating Current	km <sup>2</sup> : Square Kilometer or Square Kilometer
Avg. gen. hours/day : Average Generation Hours/Day	LPVPPs: Large Photovoltaic Solar Power Plants
APE: Absolute Percentage Errors (percentage error)	MAE: Mean Absolute Error (scale-dependent error) (MWh)
CdTe: Cadmium Telluride	MAP: Maximum Absolute Percentage Error (percentage error) (%)
Calc: Calculated Generation (kWh, MWh)	MAPE: Mean Absolute Percentage Error (percentage error) (%)
Calc/Actual: Calculated Generation/Actual Generation	MdRAE: Median Relative Absolute Error (relative error)
Calc CF: Calculated Capacity Factor	MERRA-2: Modern-Era Retrospective Analysis for Research and Applications Version 2
CEC: California Energy Commission	MinAP: Minimum Absolute Percentage Error (percentage error) (%)
CF:Capacity Factor	Mono-Si: Monocrystalline Silicon
Corr: Correlation	MP: Most Possible Value Case (%)
Corr. gen. hours: Correlation Generation Hours	Ms: milliseconds
CPU: Central Processing Unit	MSE: Mean Square Error (scale-dependent error) (MWh)
DC: Direct Current	MW: Megawatt
DC:AC ratio: Direct Current Alternating Current Ratio	MW <sub>AC</sub> : Megawatt Alternating Current
DHI: Direct Horizontal Insolation, Direct Horizontal Irradiance (W/m <sup>2</sup> )	MW <sub>DC</sub> : Megawatt Direct Current
DNI: Direct Normal Insolation, Direct Normal Irradiance (W/m <sup>2</sup> )	MWh: Megawatt hour(s)
$e_t$ : Forecast Error (scale-dependent error) (MWh)	NASA: National Aeronautics and Space Administration
$ e_t $ : Absolute Forecast Error (scale-dependent error) (MWh)	NREL: National Renewable Energy Laboratory
FS: First Solar	PC: Case More Or Less According To Personal Communication (%)
GB: Gigabyte	PCs: Personal Computers
GCR: Ground Cover Ratio	PV: Photovoltaic
G <sup>2</sup> EDPS: Global Grid Electricity Demand Prediction System	PVPP: Photovoltaic Solar Power Plant
GHI: Global Horizontal Insolation, Global Horizontal Irradiance (W/m <sup>2</sup> )	RAM: Random Access Memory
GHZ or GHz: Gigahertz	$r_t$ : Relative Error (relative error)
G <sup>2</sup> PS: Global Grid Prediction Systems	R <sup>2</sup> : R squared (coefficient of determination)
G <sup>2</sup> P <sup>3</sup> S: Global Grid Peak Power Prediction System	RD <sup>3</sup> : Research, Development, Demonstration and Deployment
G <sup>2</sup> CSPS: Global Grid Consumption Side Prediction Systems	RMAX: Reasonable Maximum Value Case (%)
G <sup>2</sup> CSEDPs: Global Grid Consumption Side Electricity Demand Prediction System	RMIN: Reasonable Minimum Value Case (%)
G <sup>2</sup> CSP <sup>3</sup> S: Global Grid Consumption Side Peak Power Prediction System	RMSE: Root Mean Square Error (scale-dependent error) (MWh)
G <sup>2</sup> CSP <sup>2</sup> S: Global Grid Consumption Side Price Prediction System	SAM: System Advisor Model
GMAE: Geometric Mean Absolute Error (scale-dependent error) (MWh)	SAMD: SAM Default Value Case (%)
GMRAE: Geometric Mean Relative Absolute Error (relative error) (MWh)	SCADA: Supervisory Control and Data Acquisition
G <sup>3</sup> SCPS: Global Grid Generation Side Cost Prediction System	sc-Si: Monocrystalline Silicon
G <sup>3</sup> SEGPS: Global Grid Generation Side Electricity Generation Prediction System	SMAPE: Symmetric MAPE (percentage errors) (%)
G <sup>3</sup> SPS: Global Grid Generation Side Prediction Systems	SWIS: South West Interconnected System
G <sup>3</sup> SP <sup>3</sup> S: Global Grid Generation Side Peak Power Prediction System	TSL: Case According To Total System Losses (%)
GIS: Geographic Information Systems	U.S.A.: The United States of America
	UW: University of Wisconsin
	VLPVPPs : Very Large Photovoltaic Solar Power Plants

#### References

- [1] Saracoglu, B.O., 2019, "An Experimental Fuzzy-WA Aggregated Location Selection Model for Very Large Photovoltaic Power Plants in Global-Grid Concept in Very Early Engineering Design Process Stages", Advances in Intelligent Systems and Computing, Volume 864, 1st Edition - 2019 (Proceedings of the 18th Online World Conference on Soft-Computing in Industrial Applications - WSC18), Chapter 3, ISBN 978-3-030-00612-9,
- [2] Saracoglu, B.O., 2017, "SEGS VI & Topaz Solar Farm SAM Empirical Trough & PVWatts Models Case Studies & Validation", International Journal of Research in Advanced Engineering Technologies, 1(1), 28-41.
- [3] Ohunakin, O.S., Saracoglu, B.O., 2018, "A comparative study of selected multi-criteria decision-making methodologies for location selection of very large concentrated solar power plants in Nigeria", African Journal of Science, Technology, Innovation and Development, DOI: 10.1080/20421338.2018.1495305

- [4] FreeGreenius, <http://freegreenius.dlr.de/>
- [5] System Advisor Model (SAM), <https://sam.nrel.gov/>
- [6] System Advisor Model Version 2017.9.5 (SAM 2017.9.5), National Renewable Energy Laboratory, Golden, CO, <https://sam.nrel.gov/content/downloads>
- [7] Blair, N., Dobos, A., Freeman, J., Neises, T., Wagner, M., Ferguson, T., Gilman, P., Janzou, S., 2014, "System Advisor Model, SAM 2014,1,14: General Description", NREL/TP-6A20-61019, National Renewable Energy Laboratory, Golden, CO.
- [8] The National Renewable Energy Laboratory, <https://www.nrel.gov/>
- [9] The University of Wisconsin–Madison, <https://www.wisc.edu/>
- [10] The Department of Energy, <https://energy.gov/>
- [11] Dobos, A.P., 2014, "PVWatts Version 5 Manual", National Renewable Energy Laboratory, NREL/TP-6A20-62641.
- [12] First Solar, <http://www.firstsolar.com/>
- [13] SunPower, <https://us.sunpower.com/>
- [14] Yingli Solar, <http://www.yinglisolar.com/en/>
- [15] SolarWorld Industries GmbH, <https://www.solarworld.de/en/home/>
- [16] REC, <https://www.recgroup.com/en>
- [17] Trina Solar, <https://www.trinasolar.com/us>
- [18] Wuxi Suntech, <http://www.suntech-power.com/>
- [19] Hanwha Q CELLS, <https://www.hanwha-qcells.com/>
- [20] JA SOLAR, <http://en.jasolar.com/>
- [21] Canadian Solar, <https://www.canadiansolar.com/>
- [22] JinkoSolar, <https://www.jinkosolar.com/>
- [23] Greenough River Solar Farm, <http://www.greenoughsolarfarm.com.au/>
- [24] King, A., 2018, "SIREN: SEN's Interactive Renewable Energy Network Tool", in Sayigh A, (eds) Transition Towards 100% Renewable Energy, Innovative Renewable Energy, Springer, Cham, DOI: 10.1007/978-3-319-69844-1\_19
- [25] Sustainable Energy Now Inc, (SEN, 2016), Modelling Overview - the SIREN Toolkit and more, [http://www.sen.asn.au/modelling\\_overview](http://www.sen.asn.au/modelling_overview)
- [26] Saracoglu, B.O., 2017, "An Experimental Fuzzy Inference System for the Third Core Module of the First Console on the Global Grid Peak Power Prediction System & Its Forecasting Accuracy Measures' Comparisons with the First and the Second Core Modules", Journal Of Energy Systems, 1(2), 75-101.
- [27] Saracoglu, B.O., 2017, "Comparative Study On Experimental Type 1 & Interval & General Type 2 Mamdani FIS for G2P3S", Global Journal of Researches in Engineering: J General Engineering, 17(2), 27-42.
- [28] Saracoglu, B.O., 2017, "Comparative Study On Experimental 2 to 9 Triangular Fuzzy Membership Function Partitioned Type 1 Mamdani's FIS For G2EDPS", Global Journal of Researches in Engineering: J General Engineering, 17(2), 1-18.
- [29] Saracoglu, B.O., 2017, "G2EDPS's First Module & Its First Extension Modules", American Journal of Applied Scientific Research, 3(4), 33-48.
- [30] Google Earth Pro 7.1.5.1557, <https://www.google.com/intl/tr/earth/>
- [31] Paint.NET 4.0.16, <http://www.getpaint.net/index.html>
- [32] National Aeronautics and Space Administration (NASA, 2015), Modern-Era Retrospective analysis for Research and Applications, Version 2, <https://gmao.gsfc.nasa.gov/reanalysis/MERRA-2/>
- [33] King, A., 2017, sen\_makeweather\_getmerra2.exe, Sourceforge.net, [https://sourceforge.net/projects/sensiren/files/sen\\_makeweather\\_getmerra2.exe/download](https://sourceforge.net/projects/sensiren/files/sen_makeweather_getmerra2.exe/download)
- [34] Bosilovich, M.G., Lucchesi, R., Suarez, M., 2016, MERRA-2: File Specification, GMAO Office Note No, 9 (Version 1,1), [http://gmao.gsfc.nasa.gov/pubs/office\\_notes](http://gmao.gsfc.nasa.gov/pubs/office_notes)
- [35] Richardson, D.B., Andrews, R.W., 2014, "Validation of the MERRA dataset for solar PV applications", 2014 IEEE 40th Photovoltaic Specialist Conference (PVSC), 809-814.
- [36] Pfenninger, S., Staffell, I., 2016, "Long-term patterns of European PV output using 30 years of validated hourly reanalysis and satellite data", Energy, 114, 1251-1265.
- [37] Maxwell, E.L., 1987, "A Quasi-Physical Model for Converting Hourly Global Horizontal to Direct Normal Insolation", Technical Report No, SERI/TR-215-3087, Solar Energy Research Institute, Golden, CO.
- [38] National Renewable Energy Laboratory (NREL, 2012), DNI-GHI to DHI calculator, [https://sam.nrel.gov/sites/default/files/content/documents/xls/DNI-GHI\\_to\\_DHI\\_Calculator.xlsx](https://sam.nrel.gov/sites/default/files/content/documents/xls/DNI-GHI_to_DHI_Calculator.xlsx)
- [39] IXL Solar, <http://www.ixlsolar.com.au/portfolio/ground-mount-solar-system-case-study/>
- [40] ENF Ltd., <https://www.enfsolar.com/pv/panel-datasheet/Thin-film/117>
- [41] Mittal, A.M., 2016, "First Solar CdTe PV Modules Technology Overview and Energy Advantage".
- [42] Rayner, M., 2013, "Greenough River Solar Farm-The First Year Of Operation".
- [43] Economic Regulation Authority (ERA), 2017, "Greenough River Solar Farm, Application for Electricity Generation Licence, Public Consultation".
- [44] SMA America, Sunny Central 500CP-US/630CP-US/720CP-US/750CP-US/800CP-US/850CP-US/900CP-US, e-catalogue.
- [45] System Advisor Model Version 2017,9,5 (SAM 2017,9,5), User Documentation, PVWatts, National Renewable Energy Laboratory, Golden, CO.
- [46] Bkayrat, R., 2013, "Lessons learnt with PV power plants in the US desert", Desert Solar in Saudi Arabia.

- [47] Morley, N., Ghiotto, N., Boppana, S., Frederick, J., Reynolds, A., 2017, "Fleet Performance of Large Scale PV in Australia", Asia-Pacific Solar Research Conference, Melbourne.
- [48] Culligan, M., Botkin, J., 2007, "Impact of Tilt Angle on System Economics for Area Constrained Rooftops", Sunpower Corporation 3939 North 1st Street San Jose, CA.
- [49] First Solar, 2012, "First Solar® FS Series 3™ PV Module, Product Datasheet, PD-5-401-03 NA".
- [50] Cedar Lake Ventures, Average Weather in Geraldton, <https://weatherspark.com/y/127545/Average-Weather-in-Geraldton-Australia-Year-Round>
- [51] Climate statistics for Australian locations, Geraldton Airport Comparison, [http://www.bom.gov.au/climate/averages/tables/cw\\_008051\\_All.shtml](http://www.bom.gov.au/climate/averages/tables/cw_008051_All.shtml)
- [52] Jim Dunlop Solar, 2012, "Chapter 9, System Sizing: Sizing Principles, Interactive vs. Stand-Alone Systems, Calculations and Software Tools".
- [53] Gevorkian, P., 2016, "Solar Power Generation Problems, Solutions, and Monitoring", First edition, Cambridge University Press, the U.S.A.,
- [54] Marion, B., Adelstein, J., Boyle, K.E., Hayden, H., Hammond, B., Fletcher, T., Canada, B., Narang, D., Shugar, D., Wenger, H., Kimber, A., Mitchell, L., Rich, G., Townsend, T., 2005, "Performance parameters for grid-connected PV systems", the Thirty-first IEEE Photovoltaic Specialists Conference, 1601-1606.
- [55] Jordan, D.C., Kurtz, S.R., 2013, "Photovoltaic degradation rates—an analytical review", Progress in photovoltaics: Research and Applications, 21(1), 12-29.
- [56] Gostein, M., Dunn., 2011, "Light soaking effects on photovoltaic modules: Overview and literature review", 37th IEEE Photovoltaic Specialists Conference (PVSC), 003126-003131.
- [57] Bartrop, R., Wagschal, A., Deth-Udom Mahasaranond, T., Rodriguez, R., 2017, "First Solar Plant Performance In Southeast Asia", Singapore Level 20, Tower 2, 1 Raffles Place, 048616, Singapore.
- [58] Bengoechea, J., Rodriguez, M.J., Lagunas, A.R., 2010, "First Solar CdTe Photovoltaic Technology: Environmental, Health and Safety Assessment", Solar Photovoltaic Energy Department of National Renewable Energy Centre (CENER) and Energy and Climate Change Area of Fundación Chile, Document Number: SD - 33.
- [59] Strevel, N., Trippel, L., Kotarba, C., Khan, I., 2013, "Improvements in CdTe module reliability and long-term degradation through advances in construction and device innovation", Photovoltaics International, 22, 66-74.
- [60] Strevel, N., 2017, "First Solar Technology Update", <http://saudi-sia.com/wp-content/uploads/2014/12/Module-Technology-Update-Nick-Strevel.pdf>
- [61] Lee, K., 2016, "Third Party Validation of First Solar PAN Files", CFV Solar Test Laboratory, Customer Project No:14038-First Solar Series 3 IEC 61853-1.
- [62] The Government of Western Australia, 2012, "Greenough River Solar Farm Project Information".
- [63] Australian Energy Market Operator (AEMO), 2018, "Market Data Western Australia – Facility Scada", <http://data.wa.aemo.com.au/#facility-scada>
- [64] Parkinson, G., 2016, "Solar power does work – and a lot better than we thought", RenewEconomy.
- [65] Saracoglu, B.O., 2017, "Long Term Electricity Demand & Peak Power Load Forecasting Variables Identification & Selection", International Journal of Systems Engineering, 6(2), 18-28.
- [66] Patnode, A.M., 2006, "Simulation and Performance Evaluation of Parabolic Trough Solar Power Plants", Master Of Science Thesis, University of Wisconsin-Madison, Madison, Wisconsin, U.S.
- [67] Padilla, R.V., 2011, "Simplified Methodology for Designing Parabolic Trough Solar Power Plants", Doctor of Philosophy Thesis, University of South Florida, Tampa, Florida, U.S.
- [68] Saracoglu, B.O., 2018, "Solar Star Projects SAM version 2017.9, 5 PVwatts version 5 model case study & validation", International Journal of Energy Applications and Technologies, 5(1), 13-28,
- [69] Saracoglu, B.O., 2018, "Experimental FWA & FOWA Aggregated VLCSPPs' LUR Estimation For GIS Based VEED", International Journal Of Engineering Technologies, 4(2), 70-79.